

Fig. 1




Fig. 2




Fig. 3

FACILITIES PM CENTER [Homepages](#) | [FMCS](#) | [Operations](#) | [Engineering](#) | [Maintenance](#) | [Facilities Prime Links](#)

FACILITIES

[PM Home](#) | [Mailbox](#) | [Edit Procedure](#) | [Search](#) | [Create PM](#) | [Reports](#) | [Admin](#)

PM Information for PM #170

Due Date: 8/25/2002

Open Facilities Work Orders for this PM

There are no open Facilities Work Orders for this PM

PM Procedure Window(s)

| EQID | Interval | Window Open | Window Close |
|-----------|----------|-------------|--------------|
| AHU 5457A | 12M | 7/11/2002 | 10/5/2002 |

SHOW CHECKSHEET 143(AHU 5457A)

Routing Information

There is no Routing indicated for this PM

Fig. 4

EQID Interval Window Open Window Close

| | | | |
|-----------|-----|-----------|-----------|
| AHU 5457A | 12M | 7/11/2002 | 10/9/2002 |
|-----------|-----|-----------|-----------|

HIDE CHECKSHEET 143(AHU 5457A)

Procedure Details for Procedure #143(AHU 5457A)

Interval: M
Frequency: 12
Due Date: 8/25/2002
Notes:
Special Instructions:
Show Procedure

Value Specifications for this PM

There are no Specifications for this PM

PM Checksheet 143 (* denotes OHS Reading)

| | |
|------------------|-------|
| REPLACE BELT | Date: |
| COMMENTS IF ANY: | Date: |

Routing Information

There is no Routing indicated for this PM

Fig. 5




Fig. 6

PM Information for: **All Released** **GO!**

| | Equipment | Due Date | Tech | Get Back |
|----------------------|-----------|------------|---------|--------------------------|
| View | AHU 5455 | 11/25/2001 | Leonard | Get Back |
| View | AHU 5457A | 11/25/2001 | Leonard | Get Back |
| View | AHU 5456 | 11/25/2001 | Leonard | Get Back |
| View | P 6411B | 11/25/2001 | Steve | Get Back |
| View | FN 6471P | 1/25/2002 | Leonard | Get Back |
| View | FN 6471S | 1/25/2002 | Leonard | Get Back |
| View | FN 6471W | 1/25/2002 | Leonard | Get Back |
| View | FN 6471M | 1/25/2002 | Leonard | Get Back |
| View | FN 6471L | 1/25/2002 | Leonard | Get Back |
| View | FN 6471K | 1/25/2002 | Leonard | Get Back |
| View | FN 6471J | 1/25/2002 | Leonard | Get Back |
| View | FN 6471R | 1/25/2002 | Leonard | Get Back |
| View | P 6720A | 12/1/2001 | Steve | Get Back |
| View | FN 5662A | 12/25/2001 | Steve | Get Back |
| View | P 6720B | 12/1/2001 | Leonard | Get Back |
| View | P 5781 | 12/1/2001 | Leonard | Get Back |
| View | P 5780 | 12/1/2001 | Leonard | Get Back |
| View | P 7213 | 12/1/2001 | Leonard | Get Back |

Display Options

Filter for next

1 Year(s)

GO!

Approval Options

[RELEASE SELECTED](#)


[RELEASE ALL](#)

[REFRESH](#)

[RESCHEDULE](#)

Fig. 7

0079936-240676

**FACILITIES PM
CENTER**

Homepages | FMCS | Operations | Engineering | Maintenance | Facilities Prime Links

PM Home | Mailbox | Edit Procedure | Search | Create PN | Reports | Admin

PM Information for: Assigned/Unreleased GO

| | Equipment | Due Date | Tech | Reassign | Release for Work |
|------|-----------|------------|-----------------------------------|----------------------------------|------------------|
| View | QA 28 | 12/21/2001 | <input type="checkbox"/> Reassign | <input type="checkbox"/> Release | |
| View | CSB 2604 | 9/15/2001 | <input type="checkbox"/> Reassign | <input type="checkbox"/> Release | |
| View | AD 5772 | 1/25/2002 | <input type="checkbox"/> Reassign | <input type="checkbox"/> Release | |
| View | AD 5775 | 1/25/2002 | <input type="checkbox"/> Reassign | <input type="checkbox"/> Release | |
| View | AD 5770 | 1/25/2002 | <input type="checkbox"/> Reassign | <input type="checkbox"/> Release | |

Reassign selected PM's to: Reassign

☐ Check this box to assign GRAB BAG
C
E
H
R
W
W
M's to the selected Technician

SHOW MY MAILBOX

Display Options


Filter for next
1 Year(s) GO

Approval Options

RELEASE SELECTER
RELEASE ALL
REFRESH
RESCHEDULE

Fig. 8

1004995, 040000, 5666400

**FACILITIES PM
CENTER**

Homepages | FMCS | Operations | Engineering | Maintenance | Facilities Prime Links

FACILITIES

PM Home | Mailbox | Edit Procedure | Search | Create PM | Reports | Admin

PM Information

What type of PM are you entering?

Already Exists (in VMMS) ☒ New (there is no existing PM) ☐

Equipment Information

Equipment ID:

Craft:

Procedure Information

General Notes:

Special Instructions:

Add to Block:

Schedule Information

Performed on a basis.

Performed every intervals.

Schedule on: Date in MM/DD/YYYY format

Assign To:

Fig. 9

-2-

Fig. 10

13 PUMP: INBOARD BEA
14 PUMP: OUTBOARD BE
15 PUMP: OUTBOARD VO
16 LIST MOTOR AMPERA SPECS < OR = NAMPL
17 NAMEPLATE =
18 L1 =
19 L2 =
20 L3 =
21 COMMENTS IF ANY =

Add Row Delete Row Delete Column
Add Textbox Add Checkbox Add Yes / No

Define Out of Spec Limits for this Procedure

| Row | Column | Function | Spec | Spec Type | Criticality |
|-----|--------|----------|------|-------------|-------------|
| 1 | | | | Real Number | |

Add Row Delete Row

Submit PM Finish Later Preview Checksheet

Fig. 11

2001-09-06 09:00:00

Search Parameters

Data from To

Equipment ID:

Craft:

Related Checksheet(s)

Checksheet(s):

Please check the items for which you wish to Query.

| | |
|---------------------------------------|-------------------------------------|
| POWER TURNED OFF TO ANALYZER | <input type="checkbox"/> |
| UV LAMP AND GASKET REPLACED | <input checked="" type="checkbox"/> |
| COVER REPLACED ON LAMP CHAMBER | <input type="checkbox"/> |
| LAMP CHAMBER PURGED WITH DRY NITROGEN | <input type="checkbox"/> |
| RESET 6 MONTH UV LAMP TIMER | <input type="checkbox"/> |
| ANALYZER CHECKED FOR NORMAL OPERATION | <input type="checkbox"/> |
| COMMENTS IF ANY: | <input type="checkbox"/> |

Fig. 12

FACILITIES PM CENTER Homepages | FMCS | Operations | Engineering | Maintenance | Facilities Prime Links

PM Home | Mailbox | Edit Procedure | Search | Create PM | Reports | Admin

Available PM's (* indicates overdue PM's)

| PM # | Equipment ID | Due Date | Bulk Select |
|------|--------------|------------|--------------------------|
| 165 | GSB 2604 | 9/14/2001 | <input type="checkbox"/> |
| 89 | OA 09 | 10/12/2001 | <input type="checkbox"/> |
| 106 | OA 09 | 10/12/2001 | <input type="checkbox"/> |
| 364 | P 7212 | 12/1/2001 | <input type="checkbox"/> |
| 376 | P 6846B | 12/1/2001 | <input type="checkbox"/> |
| 38 | OA 28 | 12/21/2001 | <input type="checkbox"/> |
| 487 | AD 5772 | 1/25/2002 | <input type="checkbox"/> |
| 408 | AD 5775 | 1/25/2002 | <input type="checkbox"/> |
| 420 | AD 5770 | 1/25/2002 | <input type="checkbox"/> |

Drag & Drop PM onto Calendar to reschedule.

No changes made

November 2001

| Sun | Mon | Tue | Wed | Thu | Fri | Sat |
|-----|-----|-----|-----|-----|-----|-----|
| 28 | 29 | 30 | 31 | 1 | 2 | 3 |
| 4 | 5 | 6 | 7 | 8 | 9 | 10 |
| 11 | 12 | 13 | 14 | 15 | 16 | 17 |
| 18 | 19 | 20 | 21 | 22 | 23 | 24 |
| 25 | 26 | 27 | 28 | 29 | 30 | 1 |
| 2 | 3 | 4 | 5 | 6 | 7 | 8 |

Fig. 13

| PM Home Mailbox Edit Procedure Search Create PM Reports Admin | | |
|---|--------------|--------------|
| Tony, these PM's require your approval. | | |
| Pending Equipment Classification | | |
| ID # | Originator | Equipment ID |
| 620 | Andre | AD 5771 |
| 628 | Andre | AD 6701 |
| 629 | Andre | AD 5771 |
| 630 | Andre | AD 6772 |
| 631 | Andre | AD 5775 |
| 632 | Andre | AD 6700 |
| 633 | Andre | AD 6701 |
| 634 | Andre | AD 6703 |
| 635 | Andre | AD 5876 |
| 636 | Andre | AD 5877 |
| Procedures In Development | | |
| Temp # | Equipment ID | Interval |
| 430 | AHU 401F | 0 |
| Tony, these PM's require Mark's action (* indicates action is overdue). | | |
| Awaiting Preventative Maintenance | | |
| PM # | Due Date | Equipment ID |
| 169 | 1/15/2002 | EFF 01 |

Fig. 14

2001 Dec 03 09:55:00

| FACILITIES PM CENTER | | | | | |
|---|----------------------|------------------------------------|--------------|-------------|-----------------------------------|
| Homepages FMCS Operations Engineering Maintenance | | | | | |
| PM Home Mailbox Edit Procedure Search Create PM Reports Admin | | | | | |
| This is the PM Exception list for Monday, December 03, 2001. | | | | | |
| Filter Dept: <input type="text"/> | | Filter Craft: <input type="text"/> | | | |
| < PREVIOUS DAY | | NEXT DAY > | | | |
| PM # | Equipment ID / Block | Window Open | Window Close | Assigned To | Current Status |
| 213 | P 6411B | 8/9/2001 | 8/31/2001 | Steve | Awaiting Preventative Maintenance |
| 157 | CSB 1701 | 8/23/2001 | 10/8/2001 | UNASSIGNED | Awaiting Preventative Maintenance |
| 158 | CSB 2201 | 8/23/2001 | 10/8/2001 | UNASSIGNED | Awaiting Preventative Maintenance |
| 159 | CSB 2201 | 8/23/2001 | 10/8/2001 | UNASSIGNED | Awaiting Preventative Maintenance |
| 160 | CSB 2202 | 8/23/2001 | 10/8/2001 | UNASSIGNED | Awaiting Preventative Maintenance |
| 161 | CSB 2204 | 8/23/2001 | 10/8/2001 | UNASSIGNED | Awaiting Preventative Maintenance |
| 162 | CSB 2205 | 8/23/2001 | 10/8/2001 | UNASSIGNED | Awaiting Preventative Maintenance |
| 163 | CSB 2206 | 8/23/2001 | 10/8/2001 | UNASSIGNED | Awaiting Preventative Maintenance |
| 164 | CSB 2207 | 8/23/2001 | 10/8/2001 | UNASSIGNED | Awaiting Preventative Maintenance |

Fig. 15